

Our Ref: HL/M110264  
Test Report: MAT/LAB 457D – 462D

15<sup>th</sup> September 2011

Cartell UK Ltd.  
Unit F, Harlow House,  
Shelton Road,  
Willowbrook Industrial Estate,  
Corby,  
Northants.  
NN17 5XH

**WATER REGULATIONS ADVISORY SCHEME (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**SEALANTS – FLAT FACED JOINTS – GENERAL**

**5440**

MXLOC 38 (green coloured) & MXLOC 48 (green) acrylic based adhesives. Apply as per manufacturer's instructions. For use with water up to 23°C.


**APPROVAL NUMBER: 1109511**  
**APPROVAL HOLDER: CARTELL UK LTD.**

The Scheme reserves the right to review approval. This approval is valid between September 2011 and September 2016.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully



**Jason Furnival**  
**Approvals & Enquiries Manager**  
**Water Regulations Advisory Scheme**

Our Ref: MAT/LAB 457D, 458D, 459D, 460D, 461D & 462D

12<sup>th</sup> September 2011

Robert Filik  
Cartell UK Ltd  
Unit F Harlow House  
Sheldon Road  
WillowBrook Ind Est  
Corby  
Northants  
NN17 5XH

Dear Robert

BS 6920 leaching tests for non-metallic products for use in contact with potable water.

Please find enclosed a copy of our final report for BS 6920 leaching tests on test samples of MX Loc 38, 22, 577, 48, 542, & 90.

We are pleased to inform you that your product gave satisfactory results in the BS 6920 leaching tests. The enclosed report does not constitute approval and has not been forwarded to the Water Regulations Advisory Scheme (WRAS).

In order to obtain WRAS approval, a letter citing a Directory Reference Number, you will need to send a copy of the enclosed report, a completed copy of the form M2 (issued by WRAS) and a remittance to the WRAS at the following address;

Water Regulations Advisory Scheme  
Fern Close,  
Pen-y-Fan Industrial Estate,  
Oakdale,  
Gwent,  
NP11 3EH

If you have any queries or we can be of any further assistance with BS 6920 or other testing please do not hesitate to contact me.

Best regards



*PP*  
Ruth Manning  
Materials Testing Technician  
WRc-NSF Ltd  
Reception +44 (0) 1495 236260 Fax Number: +44 (0) 1495 249234

**Offices at:** Unit 30, Fern Close, Pen-y-Fan Industrial Estate, Oakdale, Newport, NP11 3EH  
Unit 25, Robert Cort Estate, Britten Road, Reading, RG2 0AU

Tel: +44 (0)1495 236260. Fax: +44 (0)1495 249234. E-mail: [info@wrcnsf.com](mailto:info@wrcnsf.com) Website: [www.wrcnsf.com](http://www.wrcnsf.com)

WRc-NSF Ltd. Registered in England No. 3754780. Registered Office: Frankland Road, Blagrove, Swindon, Wiltshire, SN5 8YF, England.

